

Water Testing Timeline per NYSDOH Guidelines

Test Non-Potable Water and Potable Water

Threshold is anything over 15ppb

2016 Testing		Over 15ppb Non-Potable	Over 15ppb Potable
Date of Test:	6/17/2016	69	5
Remediation:	Signage		
Retest:	9/29/2016	0	1
Remediation:	Signage		- Room 2 at GWF

2021 Testing		Over 15ppb Non-Potable	Over 15ppb Potable
Date of Test:	6/8/2021	55	3
Remediation:	Signage		- Kitchen Sink 2 at HS - Kitchen 3 Sink at HS - Kitchen 2 Sink at HPE

November 2023 NYSDOH Guideline Changes: Threshold from 15ppb to 5ppb

Non-Potable Water not retested, continued with signage

2024 Testing		Over 5ppb Potable
Date of Test:	5/16/24 & 5/17/24	40
Remediation:	Signage	
Retest:	8/16/2024	36
Retest:	10/7/2024	30
Remediation:	Clean Aerator	
Retest:	11/7/2024	29
Remediation:	Replace Piping, Add Filters, Clean Aerator	
Retest:	1/16/2025	5
Remediation:	Eliminated 2 Outlets from Capital Project Work	
Retest:	4/3/2025	3
Remediation:	Replace Piping, Double Filter at Nurse Office at HS	
Retest:	4/22/2025	3
Results not yet received		- Nurses Office at HS - Classroom Sink Room 20 at HPE - Classroom Sink Room 22 at HPE